# **TRIDONIC**

# 



## PCA T8 BASIC Ip x:tec II, 18 - 58 W

BASIC T8

## **Product description**

- · Processor-controlled ballast with xitec II inside
- Highest possible energy class CELMA EEI = A1 BAT®
- Noise-free precise control via DSI signal, switchDIM or corridorFUNCTION
- Nominal life up to 100,000 h (at ta 50 °C with a failure rate max. 0.2 % per 1,000 h)
- 5-year guarantee

#### Interfaces

- DSI
- switchDIM (with memory function)
- corridorFUNCTION (3 preprogrammed profiles)
- Integrated SMART interface for function with SMART Sensor 5D 19f and corridorFUNCTION plugs


#### **Functions**


- Intelligent Temperature Guard (overtemperature protection)
- Intelligent Voltage Guard (overvoltage indication and undervoltage shutdown)
- Optimum filament heating in any dimmer setting
- Disconnection of filament heating from a dimming level of approx.
   90 % for maximum energy efficiency (SMART-Heating concept)
- corridorFUNCTION with ambient light control
- Automatically triggered emergency lighting value in DC mode, 15 %
- For emergency lighting systems as per EN 50172
- · Automatic start after replacement of defective lamps
- · Automatic shutdown if the lamp is faulty



# Standards, page 3

Wiring diagrams and installation examples, page 8





# Technical data

Mains voltage range	220 – 240 V
AC voltage range	198 – 264 V
DC voltage range	176 – 280 V (lamp start ≥ 198 V DC)
Mains frequency	0 / 50 / 60 Hz
Overvoltage protection	320 V AC, 1 h
Typ. power input on standby	< 0.2 W
Protective hot restart	0.5 s for AC / 0.2 s for DC
Dimming range	10 – 100 %
Lamp start possible from	10 %
Operating frequency	~ 40 - 130 kHz
Type of protection	IP20

## Ordering data

Туре	Article number	Packaging,	Packaging,	Weight
турс	Alticle Hulliber	carton	pallet	per pc.
For luminaires with 1 lamp				
PCA 1x18 T8 BASIC Ip xitec II	22185241	10 pc(s).	760 pc(s).	0.222 kg
PCA 1x36 T8 BASIC Ip x:tec II	28000042	10 pc(s).	760 pc(s).	0.219 kg
PCA 1x58 T8 BASIC Ip x:tec II	28000043	10 pc(s).	760 pc(s).	0.231 kg
For luminaires with 2 lamps				
PCA 2x18 T8 BASIC Ip x:tec II	22185244	10 pc(s).	760 pc(s).	0.253 kg
PCA 2x36 T8 BASIC Ip x:tec II	28000044	10 pc(s).	760 pc(s).	0.253 kg
PCA 2x58 T8 BASIC Ip x:tec II	28000045	10 pc(s).	640 pc(s).	0.334 kg

# Specific technical data


Lamp	Lamp	Туре	Article	Dimensions	Hole spacing	Lamp	Circuit	EEI	Current at	λat	tc point	Ambient
wattage	type		number	LxWxH	D	power@	power <sup>2</sup>		50 Hz 230 V@	50 Hz 230 V	max.	temperature ta®
For lumin	aires wit	h 1 lamp										
1 x 18 W	T8	PCA 1x18 T8 BASIC Ip x:tec II	22185241	360 x 30 x 21 mm	350 mm	16 W	18.5 W	A1 BAT	0.08 A	0.96	80 °C	-25 70 °C
1 x 36 W	T8	PCA 1x36 T8 BASIC Ip x:tec II	28000042	360 x 30 x 21 mm	350 mm	32 W	35.0 W	A1 BAT	0.16 A	0.98	85 °C	-25 70 °C
1 x 58 W	T8	PCA 1x58 T8 BASIC Ip x:tec II	28000043	360 x 30 x 21 mm	350 mm	50 W	54.0 W	A1 BAT	0.24 A	0.98	85 °C	-25 70 °C
For luminaires with 2 lamps												
2 x 18 W	T8	PCA 2x18 T8 BASIC Ip x:tec II	22185244	360 x 30 x 21 mm	350 mm	32 W	37.5 W	A1 BAT	0.16 A	0.98	75 °C	-25 60 °C
2 x 36 W	T8	PCA 2x36 T8 BASIC Ip x:tec II	28000044	360 x 30 x 21 mm	350 mm	64 W	70.0 W	A1 BAT	0.31 A	0.97	80 °C	-25 60 °C
2 x 58 W	T8	PCA 2x58 T8 BASIC Ip x:tec II	28000045	425 x 30 x 21 mm	415 mm	100 W	107.5 W	A1 BAT	0.48 A	0.99	80 °C	-25 55 °C

<sup>©</sup> According to the EU directives on ecodesign requirements (EC) No. 245/2009 and (EC) No. 347/2010.

© Valid at 100 % dimming level.

© +10 °C to ta max: unrestricted dimming. -25 °C to +10 °C: unrestricted dimming from 100 % to 30 %.

-25 °C to +10 °C, dimming below 30 %: malfunction possible but no damage to ECG. This applies to AC and DC operation.



# Standards

EN 55015

EN 60929

EN 61000-3-2

EN 61347-2-3

EN 61547

Suitable for emergency installations according

to EN 50172

CISPR 15

CISPR 22

IEC 60929

IEC 61000-3-2

IEC 61347-2-3

IEC 61547

#### Lamp starting characteristics

Warm start

Starting time 0.5 s with AC

Starting time 0.2s with DC

Start at dimming level from 10 - 100 %

#### AC operation

Mains voltage 220–240 V 50/60 Hz 198–264 V 50/60 Hz including safety tolerance (±10 %) 202–254 V 50/60 Hz including performance tolerance (+6 %/-8 %)

#### DC operation

220–240 V 0 Hz 198–280 V 0 Hz certain lamp start 176–280 V 0 Hz operating range Use in emergency lighting installations according to EN 50172 or for emergency luminaires according to EN 61347-2-3 appendix J.

Mains current for defective or missing lamps at DC operation  $<\!35\,\text{mA}.$ 

## Light output level in DC operation

Default value is 15 %

## **Emergency units**

The "PCA T8 BASIC Ip xitec II" ballasts are compatible with all emergency units from Tridonic. See the table in the data sheet. Also all "5-pole" emergency units can be used. When used with other emergency units tests are necessary.

## Temperature range

Unlimited dimming range from 10 °C to ta max. -25 °C to 10 °C: dimming operation from 100 % to 30 %. If dimm level goes below 30 % malfunction possible, but no electronic ballast damage. This applies to AC and DC operation.

#### Mains currents in DC operation (at 15 % light output)

	Lamp type	Wattage	Mains current at	Mains current at
Туре			$U_{\text{n}}=220V_{\text{DC}}$	$U_{\text{n}}=275V_{\text{DC}}$
PCA 1x18 T8 BASIC Ip x:tec II	T8	1x18W	0.04 A	0.03 A
PCA 1x36 T8 BASIC Ip x:tec II	T8	1x36 W	0.06 A	0.05 A
PCA 1x58 T8 BASIC Ip x:tec II	T8	1x58 W	0.08 A	0.07 A
PCA 2x18 T8 BASIC Ip x:tec II	T8	2x18W	0.07 A	0.06 A
PCA 2x36 T8 BASIC Ip x:tec II	T8	2x36 W	0.11 A	0.09 A
PCA 2x58 T8 BASIC Ip x:tec II	T8	2x58 W	0.16 A	0.13 A

#### Ballast lumen factor AC operation (AC-BLF) EN 60929 8.1

Туре	Lamp type	Wattage	AC-BLF at U = 230 Vac
PCA 1x18 T8 BASIC Ip x:tec II	T8	1x18W	0.99
PCA 1x36 T8 BASIC Ip x:tec II	T8	1x36W	1.00
PCA 1x58 T8 BASIC Ip x:tec II	T8	1x58 W	1.00
PCA 2x18 T8 BASIC Ip x:tec II	T8	2x18W	0.99
PCA 2x36 T8 BASIC Ip x:tec II	T8	2x36 W	1.00
PCA 2x58 T8 BASIC Ip xitec II	T8	2x58 W	1.00

The ballast lumen factor for AC operation (AC-BLF) does not alter from  $U_{n}=198\,\text{V}\,\text{Ac}$  to  $U_{n}=254\,\text{V}\,\text{Ac}$ . The ballast lumen factor for DC operation (DC-BLF) on the basis of an automatic power reduction of the ballasts (default value is 15%) will be smaller than AC. It does not alter in the DC operating range (198–280 VDC).

#### Dimming

Dimming curve is adapted to the eye sensitiveness. Dimming range 10 % to 100 % Digital control with DSI signal: 8 bit Manchester Code

Speed 10 % to 100 % in 0.8 s

#### Control input (D1, D2)

Digital DSI signal, push-to-make switch (switchDIM) or a motion detector (corridorFUNCTION) can be wired on the same terminals (D1 and D2).

#### Digital signal DSI

The control input is non-polar and protected against accidental connection with a mains voltage up to 264 V. The control signal is not SELV. Control cable has to be installed in accordance to the requirements of low voltage installations.

Different functions depending on each module.

#### **SMART** interface

An additional interface for the direct connection of the SMART-Sensor 5D 19f<sup>(1)</sup> or corridorFUNCTION plugs. Application and functionallity see corridorFUNCTION user manual

SMART-Sensor 5D 19f<sup>()</sup> light sensor operating mode: The sensor registers actual ambient light and maintains the individually defined constant lux level. After every mains reset the SMART interface automatically checks for an installed sensor. With the sensor installed the PCA T8 BASIC Ip xitec II automatically runs in the constant lux level mode. ON/OFF switch via mains, switchDIM or DSI signal. DSI signal = 0 switches off,

DSI signal  $\geq 1$  switches on.

With switchDIM signals it is possible to change the controlled light level temporarily.

Temporarily means that after a switching cycle OFF/ON command the ballast will start at the preset value determined by the SMART-Sensor 5D 19f. The installation of the two wire bus is according to the appropriate low voltage regulations.

1) SMART-Sensor 5D 19f: article number 86459169

#### switchDIM

Integrated switchDIM function allows a direct connection of a push to make switch for dimming and switching.

Brief push (< 0.6 s) switches ballast ON and OFF. The ballasts switch-ON at light level set at switch-OFF. After switch ON the last settet dimming level will be activated again.

When the push to make switch is held, PCA ballasts are dimmed. After repush the PCA is dimmed in the opposite direction.


The switchDIM fade time is set to 3 s from min. to max. in the factory settings.

In installations with PCAs with different dimming levels or opposite dimming directions (e.g. after a system extension), all PCAs can be synchronized to 50 % dimming level by a 10 s push.


Use of push to make switch with indicator lamp is not permitted.

switchDIM and corridorFUNCTION are very simple tools for controlling ballasts with conventional momentary-action switches or motion sensors. To ensure correct operation a sinusoidal mains voltage with a frequency of 50 Hz or 60 Hz is required at the control input. Special attention must be paid to achieving clear zero

# Dimming characteristics PCA T8 BASIC Ip x:tec II



# Energy saving PCA T8 BASIC Ip x:tec II



Dimming characteristics as seen by the human eye Note: The dimming level of BASIC can be different to the graphic (dimming level 10 to 100 %)

crossings. Serious mains faults may impair the operation of switchDIM and corridorFUNCTION.


#### corridorFUNCTION

To activate the corridorFUNCTION a voltage of 230 V simply has to be applied for five minutes at switchDIM connection. The unit will then switch automatically to the corridorFUNCTION.


Note: If the corridorFUNCTION is wrongly activated in a switchDIM system (for example a switch is used instead of pushbutton), there is the option of installing a pushbutton and deactivating the corridorFUNCTION mode by five short pushes of the button within three seconds.

The corridorFUNCTION offers the added benefit of a second and third preprogrammed profile, which can be activated by the corridorFUNCTION plugs. It is also possible to combine the corridorFUNCTION with the SMART-Sensor 5D 19f light sensor.


Application and functionallity of profiles see user manual of the corridorFUNCTION.



switchDIM PCA T8 BASIC Ip x:tec II



corridorFUNCTION PCA T8 BASIC Ip x:tec II



DSI PCA T8 BASIC Ip xitec II

Dimmable ballasts from Tridonic have to be earthed.

# Electronic dimming

#### Loading of automatic circuit breakers (Limitation via inrush current)

Automatic circuit breaker type	C10	C13	C16	C20	B10	B13	B16	B20	Inrush curre	ent (1.5 mm²)	Inrush curre	nt (2.5 mm²)
Installation Ø	1.5 mm <sup>2</sup>	1.5 mm <sup>2</sup>	$1.5\mathrm{mm}^2$	$2.5\mathrm{mm}^2$	1.5 mm <sup>2</sup>	1.5 mm <sup>2</sup>	1.5 mm <sup>2</sup>	$2.5\mathrm{mm}^2$	I <sub>max</sub>	time	l <sub>max</sub>	time
PCA 1x18 T8 BASIC Ip x:tec II	50	82	161	201	25	41	120	107	19.3 A	166 µs	19.7 A	165 µs
PCA 1x36 T8 BASIC Ip x:tec II	36	54	80	92	18	27	40	46	19.2 A	189 µs	19.6 A	187 µs
PCA 1x58 T8 BASIC Ip x:tec II	22	34	46	54	11	17	23	27	24.7 A	224 µs	24.4 A	227 µs
PCA 2x18 T8 BASIC Ip x:tec II	34	50	76	86	17	25	38	43	20.3 A	204 µs	23.3 A	184 µs
PCA 2x36 T8 BASIC Ip x:tec II	22	32	42	52	11	16	22	26	26.4 A	210 µs	27.2 A	207 μs
PCA 2x58 T8 BASIC Ip x:tec II	16	22	28	34	8	11	15	17	28.6 A	290 µs	29.1 A	289 µs

Continuous operation: to calculate the protective saftey switch see main current, page  $2\,$ 

#### **Intelligent Temperature Guard**

The intelligent temperature guard protects the PCA T8 BASIC Ip xitec II from thermal overheating by reducing the output power or switching off in case of operation above the thermal limits of the luminaire or ballast. Depending on the luminaire design, the ITG operates at about 5 to 10 °C above tc temperature.

#### Intelligent Voltage Guard

Intelligent Voltage Guard is the name of the electronic monitor from Tridonic. This innovative feature of the PCA family of control gear from Tridonic immediately shows if the mains voltage rises above certain thresholds. Measures can then be taken quickly to prevent damage to the control gear.

- If the mains voltage rises above approx. 318 Vrms (voltage depends on the ballast type), the lamp starts flashing on and off.
- To avoid a damage of the device the mains supply has to be switched off at this signal.

Harmonic distortion in the mains supply (at 230 V/50 Hz)

Туре	Lamp type	Wattage	THD	3	5	7	9	11
PCA 1x18 T8 BASIC Ip x:tec II	T8	1x18W	9	5	2	1	1	1
PCA 1x36 T8 BASIC Ip x:tec II	T8	1x36 W	8	4	4	3	2	2
PCA 1x58 T8 BASIC Ip x:tec II	T8	1x58 W	7	5	2	3	1	1
PCA 2x18 T8 BASIC Ip x:tec II	T8	2x18W	8	5	2	1	1	1
PCA 2x36 T8 BASIC Ip x:tec II	T8	2x36 W	7	5	1	1	1	2
PCA 2x58 T8 BASIC Ip x:tec II	T8	2x58 W	6	4	1	1	1	1

Operating voltage

Туре	Lamp type	Wattage	Uout
PCA 1x18 T8 BASIC Ip x:tec II	T8	1x18W	430 V
PCA 1x36 T8 BASIC Ip x:tec II	T8	1x36 W	430 V
PCA 1x58 T8 BASIC Ip x:tec II	T8	1x58 W	430 V
PCA 2x18 T8 BASIC Ip x:tec II	T8	2x18W	430 V
PCA 2x36 T8 BASIC Ip x:tec II	T8	2x36 W	430 V
PCA 2x58 T8 BASIC Ip x:tec II	T8	2x58 W	430 V

Humidity: 5 % up to max. 85 %,

not condensed

(max. 56 days/year at 85 %)

Storage temperature: -40 °C up to max. +80 °C

The devices have to be within the specified temperature range (ta) before they can be operated.

#### Expected life-time


Exposiou ino timo						
Туре	Lamp type	Wattage		ta = 40 °C	ta = 50°C	ta = 60 °C
PCA 1x18 T8 BASIC Ip x:tec II	Т8	1 x 18 W	tc	50 °C	60 °C	70 °C
FCA 1X10 10 BASIC IP X!LEC II	10	1 X 10 W	Life-time	≥ 100,000 h	≥ 100,000 h	≥ 100,000 h
PCA 1x36 T8 BASIC Ip xitec II	Т8	1 x 36 W	tc	55 °C	65 °C	75 °C
	10	1 X 30 W	Life-time	≥ 100,000 h	≥ 100,000 h	≥ 100,000 h
PCA 1x58 T8 BASIC Ip xitec II	Т8	1 x 58 W	tc	55 °C	65 °C	75 °C
	10	1 A JO W	Life-time	≥ 100,000 h	≥ 100,000 h	≥ 100,000 h
PCA 2x18 T8 BASIC Ip x:tec II	Т8	2 x 18 W	tc	60 °C	70 °C	80 °C
FGA 2X10 10 BASIC IP X:tec II	10	∠ X 10 W	Life-time	≥ 100,000 h	≥ 100,000 h	≥ 50,000 h
DCA 2x26 TO DACIC in vitos II	Т8	2 x 36 W	tc	65 °C	70 °C	80 °C
PCA 2x36 T8 BASIC Ip x:tec II	10	2 X 30 W	Life-time	≥ 100,000 h	≥ 100,000 h	≥ 50,000 h
DCA OvEO TO DACIC in vistor II	T8	0 v E0 W	tc	65 °C	75 °C	80 °C
PCA 2x58 T8 BASIC Ip x:tec II	18	2 x 58 W	Life-time	≥ 100,000 h	≥ 50,000 h	≥ 50,000 h

x = not permitted

#### Installation instructions


#### Wiring type and cross section

The wiring can be solid cable with a cross section of 0.5 to 1.5 mm<sup>2</sup>. For the push-wire connection you have to strip the insulation (8–9 mm).



#### Release of the wiring

Loosen wire through twisting and pulling or using a  $\emptyset$  1 mm release tool.



#### Wiring advice

The lead length is dependent on the capacitance of the cable.

Ballast	Terminal	Ma	aximum capacitance	allowed
Туре	Cold	Hot	Cold	Hot
PCA 1xx T8 BASIC Ip x:tec II	13, 14	15, 16	200 pF	100 pF
PCA 2xx T8 BASIC Ip xitec II	12, 13, 14	10, 11, 15, 16	200 pF	100 pF

With standard solid wire 0.5/0.75 mm<sup>2</sup> the capacitance of the lead is 30-80 pF/m.

This value is influenced by the way the wiring is made.

Lamp connection should be made with symmetrical wiring.

Hot leads (10, 11, 15, 16) and cold leads (12, 13, 14) should be separated as much as possible.

PCA T8 BASIC Ip x:tec II 2x18–58 W
Dimmable ballasts from Tridonic have to be earthed.


When using two or more dimmable ballasts in one luminaire with separate dimming controls, the lamp leads must be kept separate.

#### Sensor wires

Sensor wires must be routed separately from the lamp wires and mains cables otherwise the lighting control system may malfunction. If separate routing is not possible (for reasons of space) shielded lamp wires and mains cables must be used.

Dimmable ballasts from Tridonic have to be earthed.

To avoid the damage of the control gear, the wiring must be protected against short circuits to earth (sharp edged metal parts, metal cable clips, louver, etc.).



#### PCA T8 BASIC Ip x:tec II 1x18-58 W

be kept as short as possible

(ideally 5-10 cm distance)


electronic ballast

Twist the lamp leads

# Operation on DC voltage

Our ballasts are construed to operate DC voltage and pulsed DC voltage.

To operate ballasts with pulsed DC voltage the polarity is absolute mandatory.



# as possible General advise

RFI

Electronic ballasts are virtually noise free. Magnetic fields generated during the ignition cycle can cause some background noise but only for a few milliseconds.

· Connection to the lamps of the hot leads must

Do not run mains leads adjacent to the

· Keep the distance of lamp leads from the

· Mains wiring to be twisted when through wiring

. Keep the mains leads inside the luminaire as short

metal work as large as possible

· Mains leads should be kept apart from lamp leads

#### Additional information

Additional technical information at <u>www.tridonic.com</u> → Technical Data

Guarantee conditions at  $\underline{\text{www.tridonic.com}} \rightarrow \text{Services}$ 

Life-time declarations are informative and represent no warranty claim.

No warranty if device was opened.

# Isolation and electric strength testing of luminaires

Electronic devices can be damaged by high voltage. This has to be considered during the routine testing of the luminaires in production.

According to IEC 60598-1 Annex Q (informative only!) or ENEC 303-Annex A, each luminaire should be submitted to an isolation test with 500 V DC for 1 second. This test voltage should be connected between the interconnected phase and neutral terminals and the earth terminal.

The isolation resistance must be at least 2  $\text{M}\Omega.$ 

As an alternative, IEC 60598-1 Annex Q describes a test of the electrical strength with 1500 V AC (or 1.414 x 1500 V DC). To avoid damage to the electronic devices this test must not be conducted.